



Certificate of Compliance

Certificate: 1706447 (LR 110441-1)

Master Contract: 187789

Project: 2085275

Date Issued: 2008/12/05

Issued to: Keyscan Inc.

901 Burns St E
Whitby, ON L1N 6A6
Canada
Attention: Mr. John Dyall

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Ken Cheung, P. Eng

Authorized by: Akbar Lalani, Product Group Manager

PRODUCTS

CLASS 4812 05 - SIGNAL APPLIANCES - Systems

CLASS 4812 85 - SIGNAL APPLIANCES - Systems - Certified to US Standards

Access control systems, Keyscan Models CA200, CA4000, CA8000, EC1000, EC2000, 16V ac, 40VA, Class 2 input; relay output contacts, 24V ac, 10A; 30V dc, 5A.

APPLICABLE REQUIREMENTS



CSA INTERNATIONAL

Certificate: 1706447 (LR 110441-1)

Master Contract: 187789

Project: 2085275

Date Issued: 2008/12/05

CSA Std C22.2 No. 205-M1983 - Signal Equipment

UL Std No.294, Fifth Ed.- 1999 - Access Control System Units